


SV8150



Vortex flow meter

SVM54XXXD0KG/US-100



CE

Product characteristics

| | | |
|------------------------------|----------------------------------|-------------------|
| Number of inputs and outputs | Number of analog outputs: 1 | |
| Measuring range | 9...150 l/min | 0.283...4.709 m/s |
| Process connection | threaded connection G 1 1/4 DN25 | |

Application

| | | |
|-------------------------|---|-----------|
| System | gold-plated contacts | |
| Measuring element | 1 x Pt 1000; (to DIN EN 60751, class B) | |
| Application | for industrial applications | |
| Installation | connection to pipe by means of an adapter | |
| Media | water; glycol solutions; Coolants | |
| Medium temperature | [°C] | -40...100 |
| Min. bursting pressure | [bar] | 25 |
| Min. bursting pressure | [MPa] | 2.5 |
| Pressure rating | [bar] | 12 |
| Pressure rating | [MPa] | 1.2 |
| Note on pressure rating | up to 40 °C | |

Electrical data

| | | |
|----------------------------|------|-----------------|
| Operating voltage | [V] | 8...33 DC |
| Min. insulation resistance | [MΩ] | 100; (500 V DC) |

SV8150



Vortex flow meter

SVM54XXXD0KG/US-100

| | | |
|------------------------------------|-----------------------------|---|
| Protection class | | III |
| Power-on delay time | [s] | < 2 |
| Inputs / outputs | | |
| Number of inputs and outputs | Number of analog outputs: 1 | |
| Outputs | | |
| Total number of outputs | | 1 |
| Output signal | analog signal | |
| Number of analog outputs | | 1 |
| Analog current output | [mA] | 4...20; (water: $Q \text{ [l/min]} = 9,375 \times (I - 4 \text{ mA})$; water-glycol: $Q \text{ [l/min]} = 9,375 \times (I - 4 \text{ mA}) - Q_0$ see Figure 2) |
| Max. load | [Ω] | $< (U_b - 8 \text{ V}) / 20 \text{ mA}$; $U_b = 24 \text{ V}$: 800 |
| Measuring/setting range | | |
| Measuring range | 9...150 l/min | 0.283...4.709 m/s |
| Temperature monitoring | | |
| Internal heating temperature probe | | 1 K/mW |
| Measuring range | [°C] | -40...100 |
| Accuracy / deviations | | |
| Flow monitoring | | |
| Accuracy (in the measuring range) | | $Q < 50\% \text{ MEW}: < 1\% \text{ MEW} / Q > 50\% \text{ MEW}: < 2\% \text{ MW}$; (water) |
| Repeatability | | 0,2; (% of the final value) |
| Temperature monitoring | | |
| Accuracy | [K] | $\pm 0,3 \pm 0,005 \times T$ |
| Reaction times | | |
| Flow monitoring | | |
| Response time | [s] | 0.5 |
| Operating conditions | | |
| Ambient temperature | [°C] | -15...85 |
| Note on ambient temperature | | medium temperature $> 0 \text{ °C}$: -30...85 |
| Storage temperature | [°C] | -30...85 |
| Protection | | IP 65 |
| Cavitation | | $P(\text{absolute}) \text{ discharge} / P(\text{difference}) > 5.5$ to avoid cavitation |
| Tests / approvals | | |
| EMC | | EN 61326-2-3 |
| Shock resistance | | DIN EN 60068-2-27 |
| Vibration resistance | | DIN EN 60068-2-6 |
| MTTF | [years] | 380 |
| Pressure equipment directive | | sound engineering practice; can be used for group 2 fluids; group 1 fluids on request |
| Mechanical data | | |
| Weight | [g] | 136.2 |
| Material | | PA 6T |
| Materials (wetted parts) | | ETFE; PA 6T; EPDM |

SV8150



Vortex flow meter

SVM54XXXD0KG/US-100

| | | |
|--------------------|------|----------------------------------|
| Tightening torque | [Nm] | 15 |
| Process connection | | threaded connection G 1 1/4 DN25 |

Remarks

| | |
|---------|--|
| Remarks | MW = Measured value |
| | MEW = Final value of the measuring range |


| | |
|---------------|--------|
| Pack quantity | 1 pcs. |
|---------------|--------|

Electrical connection

Connector: 1 x M12; coding: A; Contacts: gold-plated



Connection



OUT: analog output

T1 / T2: Pt1000

Colors to DIN EN 60947-5-2

Core colors :

BK = black

BN = brown

BU = blue

WH = white


Vortex flow meter

SVM54XXXD0KG/US-100

Diagrams and graphs

Pressure loss


dP [mbar] DN25



dP Pressure loss

Q volumetric flow quantity


Minimum lifetime 10 years
referred to flow and high medium
temperatures




Vortex flow meter

SVM54XXXD0KG/US-100

Determination of the kinematic viscosity (ν) of glycol-water mixtures depending on the temperature



determination of the compensation value Q_0 for glycol-water mixtures



$\nu < 4$ cSt measuring accuracy 3% MEW

$4 < \nu < 14$ cSt measuring accuracy 4% MEW


SV8150



Vortex flow meter

SVM54XXXD0KG/US-100

Response threshold Q_{\min} (l/min)
depending on the kinematic viscosity



pressure rating (bar)

